

Build Over or Near Watermains

Building over a public watermain within new development or redevelopment sites is **NOT** permitted.

If you have located or have reason to believe that a public watermain is within 4.0 metres of your works, you must contact Northern Ireland Water's Infrastructure Management Team immediately:

Northern Ireland Water recommends public watermains should not be diverted as this is costly and interrupts supply to our customers. Where new development is over or near our watermains, you should consider relocating your building. If this is not possible you must speak to your regional infrastructure manager immediately to discuss options.

You should be aware that Trunk mains and Critical Mains cannot be diverted for practical reasons.

Northern Ireland Water

Academy House
121a Broughshane Street
Ballymena
Co. Antrim
BT43 6BA

Tel: (028) 9024 4711

Fax: (028) 2565 3131

Email: infrastructure@niwater.com

Website: www.niwater.com

Watermains are protected under Articles 236 of the 2006 Order. Failure to inform us of your building over or near mains could lead to prosecution.