

Sample Date	Parameter	Units	Result	PCV Limit
18/08/2026 09:30	Asulam	ug/l	<0.016	0.1
04/08/2026 08:02	Asulam	ug/l	<0.016	0.1
21/07/2026 08:53	Asulam	ug/l	<0.016	0.1
07/07/2026 12:07	Asulam	ug/l	<0.016	0.1
23/06/2026 07:30	Asulam	ug/l	<0.016	0.1
09/06/2026 09:08	Asulam	ug/l	<0.016	0.1
19/05/2026 07:28	Asulam	ug/l	<0.016	0.1
05/05/2026 07:45	Asulam	ug/l	<0.016	0.1
14/04/2026 10:20	Asulam	ug/l	<0.016	0.1
31/03/2026 08:15	Asulam	ug/l	<0.016	0.1
16/03/2026 10:36	Asulam	ug/l	<0.016	0.1
03/03/2026 08:33	Asulam	ug/l	<0.016	0.1
17/02/2026 08:15	Asulam	ug/l	<0.016	0.1
03/02/2026 06:45	Asulam	ug/l	<0.016	0.1
20/01/2026 08:28	Asulam	ug/l	<0.016	0.1
06/01/2026 07:49	Asulam	ug/l	<0.016	0.1
09/12/2025 08:10	Asulam	ug/l	<0.016	0.1
02/12/2025 10:05	Asulam	ug/l	<0.016	0.1
01/12/2025 07:09	Asulam	ug/l	<0.016	0.1
25/11/2025 08:14	Asulam	ug/l	<0.016	0.1
11/11/2025 08:22	Asulam	ug/l	<0.016	0.1
28/10/2025 10:11	Asulam	ug/l	<0.016	0.1
14/10/2025 08:53	Asulam	ug/l	<0.016	0.1
30/09/2025 08:35	Asulam	ug/l	<0.016	0.1
16/09/2025 08:47	Asulam	ug/l	<0.016	0.1
19/08/2025 09:19	Asulam	ug/l	<0.016	0.1
05/08/2025 11:13	Asulam	ug/l	<0.016	0.1
08/07/2025 08:48	Asulam	ug/l	<0.015	0.1
24/06/2025 08:36	Asulam	ug/l	<0.015	0.1
10/06/2025 08:23	Asulam	ug/l	<0.015	0.1
27/05/2025 09:06	Asulam	ug/l	<0.015	0.1
13/05/2025 07:49	Asulam	ug/l	<0.015	0.1
29/04/2025 08:46	Asulam	ug/l	<0.015	0.1
15/04/2025 08:08	Asulam	ug/l	<0.015	0.1
01/04/2025 09:34	Asulam	ug/l	<0.015	0.1
25/03/2025 06:59	Asulam	ug/l	<0.015	0.1
04/03/2025 08:39	Asulam	ug/l	<0.015	0.1
18/02/2025 11:04	Asulam	ug/l	<0.015	0.1
04/02/2025 08:35	Asulam	ug/l	<0.015	0.1
07/01/2025 11:10	Asulam	ug/l	<0.015	0.1
10/12/2024 08:36	Asulam	ug/l	<0.015	0.1
03/12/2024 07:20	Asulam	ug/l	<0.015	0.1
26/11/2024 07:40	Asulam	ug/l	<0.015	0.1

Sample Date	Parameter	Units	Result	PCV Limit
12/11/2024 08:22	Asulam	ug/l	<0.015	0.1
29/10/2024 09:26	Asulam	ug/l	<0.015	0.1
15/10/2024 07:49	Asulam	ug/l	<0.015	0.1
01/10/2024 08:20	Asulam	ug/l	<0.015	0.1
17/09/2024 08:35	Asulam	ug/l	<0.015	0.1
03/09/2024 11:48	Asulam	ug/l	<0.015	0.1
20/08/2024 09:06	Asulam	ug/l	<0.015	0.1
06/08/2024 08:08	Asulam	ug/l	<0.015	0.1
23/07/2024 08:18	Asulam	ug/l	<0.015	0.1
09/07/2024 08:30	Asulam	ug/l	<0.015	0.1
25/06/2024 08:12	Asulam	ug/l	<0.015	0.1
11/06/2024 09:24	Asulam	ug/l	<0.015	0.1
28/05/2024 11:18	Asulam	ug/l	<0.015	0.1
14/05/2024 11:21	Asulam	ug/l	<0.015	0.1
30/04/2024 11:02	Asulam	ug/l	<0.015	0.1
16/04/2024 11:27	Asulam	ug/l	<0.015	0.1
08/04/2024 11:36	Asulam	ug/l	<0.015	0.1
19/03/2024 11:43	Asulam	ug/l	<0.015	0.1
05/03/2024 11:10	Asulam	ug/l	<0.015	0.1
23/01/2024 09:58	Asulam	ug/l	<0.015	0.1
09/01/2024 10:12	Asulam	ug/l	<0.015	0.1
19/12/2023 11:45	Asulam	ug/l	<0.015	0.1
12/12/2023 11:34	Asulam	ug/l	<0.015	0.1
05/12/2023 12:58	Asulam	ug/l	<0.015	0.1
04/12/2023 10:08	Asulam	ug/l	<0.015	0.1
21/11/2023 11:21	Asulam	ug/l	<0.015	0.1
07/11/2023 11:23	Asulam	ug/l	<0.015	0.1
31/10/2023 11:39	Asulam	ug/l	<0.015	0.1
23/10/2023 11:51	Asulam	ug/l	<0.015	0.1
17/10/2023 12:25	Asulam	ug/l	<0.015	0.1
10/10/2023 11:04	Asulam	ug/l	<0.015	0.1
26/09/2023 11:46	Asulam	ug/l	<0.015	0.1
12/09/2023 11:34	Asulam	ug/l	<0.015	0.1
14/08/2023 11:28	Asulam	ug/l	<0.015	0.1
01/08/2023 11:21	Asulam	ug/l	<0.015	0.1
18/07/2023 11:46	Asulam	ug/l	<0.015	0.1
04/07/2023 10:54	Asulam	ug/l	<0.015	0.1
20/06/2023 10:39	Asulam	ug/l	<0.015	0.1
06/06/2023 12:24	Asulam	ug/l	<0.015	0.1
23/05/2023 10:45	Asulam	ug/l	<0.015	0.1
25/04/2023 12:04	Asulam	ug/l	<0.015	0.1
28/03/2023 11:04	Asulam	ug/l	<0.015	0.1
14/03/2023 11:09	Asulam	ug/l	<0.015	0.1

Sample Date	Parameter	Units	Result	PCV Limit
28/02/2023 11:37	Asulam	ug/l	<0.015	0.1
14/02/2023 11:15	Asulam	ug/l	<0.015	0.1
31/01/2023 12:00	Asulam	ug/l	<0.015	0.1
17/01/2023 10:12	Asulam	ug/l	<0.015	0.1
13/12/2022 12:53	Asulam	ug/l	<0.015	0.1
06/12/2022 11:47	Asulam	ug/l	<0.015	0.1
22/11/2022 07:23	Asulam	ug/l	<0.015	0.1
08/11/2022 11:27	Asulam	ug/l	<0.015	0.1
25/10/2022 11:39	Asulam	ug/l	<0.015	0.1
11/10/2022 11:15	Asulam	ug/l	<0.015	0.1
27/09/2022 11:29	Asulam	ug/l	<0.015	0.1
13/09/2022 07:11	Asulam	ug/l	<0.015	0.1
30/08/2022 08:00	Asulam	ug/l	<0.015	0.1
16/08/2022 07:47	Asulam	ug/l	<0.015	0.1
02/08/2022 10:53	Asulam	ug/l	<0.015	0.1
19/07/2022 07:54	Asulam	ug/l	<0.015	0.1
05/07/2022 07:39	Asulam	ug/l	<0.015	0.1
21/06/2022 08:34	Asulam	ug/l	<0.015	0.1
07/06/2022 07:54	Asulam	ug/l	<0.015	0.1
24/05/2022 07:22	Asulam	ug/l	<0.015	0.1
09/05/2022 08:01	Asulam	ug/l	<0.015	0.1
26/04/2022 08:10	Asulam	ug/l	<0.015	0.1
11/04/2022 07:56	Asulam	ug/l	<0.017	0.1
29/03/2022 08:12	Asulam	ug/l	<0.017	0.1
15/03/2022 07:55	Asulam	ug/l	<0.017	0.1
01/03/2022 08:31	Asulam	ug/l	<0.017	0.1
15/02/2022 08:20	Asulam	ug/l	<0.017	0.1
04/01/2022 08:20	Asulam	ug/l	<0.017	0.1
21/12/2021 07:44	Asulam	ug/l	<0.017	0.1
14/12/2021 08:00	Asulam	ug/l	<0.017	0.1
29/11/2021 08:15	Asulam	ug/l	<0.017	0.1
16/11/2021 08:13	Asulam	ug/l	<0.017	0.1
02/11/2021 07:56	Asulam	ug/l	<0.017	0.1
19/10/2021 08:28	Asulam	ug/l	<0.017	0.1
21/09/2021 10:52	Asulam	ug/l	<0.017	0.1
07/09/2021 07:50	Asulam	ug/l	<0.034	0.1
24/08/2021 07:46	Asulam	ug/l	<0.017	0.1
10/08/2021 08:40	Asulam	ug/l	<0.017	0.1
27/07/2021 08:10	Asulam	ug/l	<0.017	0.1
14/07/2021 08:23	Asulam	ug/l	<0.017	0.1
28/06/2021 08:10	Asulam	ug/l	<0.017	0.1
15/06/2021 13:45	Asulam	ug/l	<0.017	0.1
01/06/2021 13:45	Asulam	ug/l	<0.017	0.1

Sample Date	Parameter	Units	Result	PCV Limit
18/05/2021 12:41	Asulam	ug/l	<0.017	0.1
04/05/2021 13:36	Asulam	ug/l	<0.017	0.1
20/04/2021 12:44	Asulam	ug/l	<0.017	0.1
19/04/2021 13:23	Asulam	ug/l	<0.017	0.1
07/04/2021 12:43	Asulam	ug/l	<0.017	0.1
09/03/2021 12:51	Asulam	ug/l	<0.017	0.1
23/02/2021 14:03	Asulam	ug/l	<0.017	0.1
09/02/2021 12:44	Asulam	ug/l	<0.017	0.1
26/01/2021 13:47	Asulam	ug/l	<0.017	0.1
15/12/2020 13:40	Asulam	ug/l	<0.017	0.1
14/12/2020 13:41	Asulam	ug/l	<0.017	0.1
07/12/2020 13:23	Asulam	ug/l	<0.017	0.1
01/12/2020 14:14	Asulam	ug/l	<0.017	0.1
30/11/2020 12:38	Asulam	ug/l	<0.017	0.1
17/11/2020 13:41	Asulam	ug/l	<0.017	0.1
03/11/2020 13:30	Asulam	ug/l	<0.017	0.1
20/10/2020 13:39	Asulam	ug/l	<0.017	0.1
06/10/2020 12:20	Asulam	ug/l	<0.017	0.1
22/09/2020 13:52	Asulam	ug/l	<0.085	0.1
11/08/2020 13:43	Asulam	ug/l	<0.017	0.1
28/07/2020 14:04	Asulam	ug/l	<0.017	0.1
15/07/2020 13:29	Asulam	ug/l	<0.017	0.1
16/06/2020 12:07	Asulam	ug/l	<0.017	0.1
02/06/2020 13:36	Asulam	ug/l	<0.017	0.1
19/05/2020 12:51	Asulam	ug/l	<0.017	0.1
04/05/2020 13:52	Asulam	ug/l	<0.017	0.1
21/04/2020 12:26	Asulam	ug/l	<0.017	0.1
06/04/2020 12:14	Asulam	ug/l	<0.017	0.1
24/03/2020 13:31	Asulam	ug/l	<0.017	0.1
10/03/2020 08:07	Asulam	ug/l	<0.017	0.1
25/02/2020 13:33	Asulam	ug/l	<0.017	0.1
11/02/2020 14:51	Asulam	ug/l	<0.017	0.1
28/01/2020 13:57	Asulam	ug/l	<0.017	0.1
14/01/2020 13:30	Asulam	ug/l	<0.017	0.1
17/12/2019 13:42	Asulam	ug/l	<0.017	0.1
16/12/2019 13:34	Asulam	ug/l	<0.017	0.1
09/12/2019 12:52	Asulam	ug/l	<0.017	0.1
25/11/2019 13:33	Asulam	ug/l	<0.017	0.1
28/10/2019 08:22	Asulam	ug/l	<0.017	0.1
15/10/2019 13:39	Asulam	ug/l	<0.0050	0.1
01/10/2019 13:45	Asulam	ug/l	<0.0050	0.1
17/09/2019 08:13	Asulam	ug/l	<0.0050	0.1
03/09/2019 07:49	Asulam	ug/l	<0.0050	0.1

Sample Date	Parameter	Units	Result	PCV Limit
20/08/2019 14:00	Asulam	ug/l	<0.0050	0.1
22/07/2019 13:39	Asulam	ug/l	<0.0050	0.1
08/07/2019 14:04	Asulam	ug/l	<0.0050	0.1
24/06/2019 13:45	Asulam	ug/l	<0.0050	0.1
10/06/2019 13:49	Asulam	ug/l	<0.0050	0.1
28/05/2019 12:11	Asulam	ug/l	<0.0050	0.1
29/04/2019 12:55	Asulam	ug/l	<0.0050	0.1
16/04/2019 12:23	Asulam	ug/l	<0.0050	0.1
02/04/2019 13:47	Asulam	ug/l	<0.0050	0.1
19/03/2019 12:39	Asulam	ug/l	<0.0050	0.1
05/03/2019 12:34	Asulam	ug/l	<0.0050	0.1
19/02/2019 12:58	Asulam	ug/l	<0.0050	0.1
05/02/2019 13:04	Asulam	ug/l	<0.0050	0.1
21/01/2019 12:47	Asulam	ug/l	<0.0050	0.1
07/01/2019 08:07	Asulam	ug/l	<0.0050	0.1
17/12/2018 12:30	Asulam	ug/l	<0.0050	0.1
03/12/2018 12:43	Asulam	ug/l	<0.0050	0.1
19/11/2018 12:20	Asulam	ug/l	<0.0050	0.1
05/11/2018 12:33	Asulam	ug/l	<0.0050	0.1
22/10/2018 12:21	Asulam	ug/l	<0.0050	0.1
08/10/2018 12:00	Asulam	ug/l	<0.0050	0.1
24/09/2018 12:39	Asulam	ug/l	<0.0050	0.1
10/09/2018 13:04	Asulam	ug/l	<0.0050	0.1
27/08/2018 12:03	Asulam	ug/l	<0.0050	0.1
13/08/2018 13:36	Asulam	ug/l	<0.0050	0.1
30/07/2018 12:40	Asulam	ug/l	<0.0050	0.1
16/07/2018 12:33	Asulam	ug/l	<0.0050	0.1
02/07/2018 13:19	Asulam	ug/l	<0.0050	0.1
18/06/2018 06:25	Asulam	ug/l	<0.0050	0.1
04/06/2018 07:09	Asulam	ug/l	<0.0050	0.1
28/05/2018 10:30	Asulam	ug/l	<0.0050	0.1
14/05/2018 07:07	Asulam	ug/l	<0.0049	0.1
30/04/2018 12:15	Asulam	ug/l	<0.0049	0.1
16/04/2018 07:40	Asulam	ug/l	<0.0049	0.1
02/04/2018 11:02	Asulam	ug/l	<0.0049	0.1
19/03/2018 12:48	Asulam	ug/l	<0.0049	0.1
05/03/2018 12:54	Asulam	ug/l	<0.0049	0.1
19/02/2018 13:16	Asulam	ug/l	<0.0049	0.1
05/02/2018 14:10	Asulam	ug/l	<0.0049	0.1
15/01/2018 12:29	Asulam	ug/l	<0.0049	0.1
01/01/2018 12:46	Asulam	ug/l	<0.0049	0.1
18/12/2017 13:01	Asulam	ug/l	<0.0049	0.1
04/12/2017 12:57	Asulam	ug/l	<0.0049	0.1

Sample Date	Parameter	Units	Result	PCV Limit
20/11/2017 13:42	Asulam	ug/l	<0.0049	0.1
06/11/2017 13:06	Asulam	ug/l	<0.0049	0.1
16/10/2017 12:46	Asulam	ug/l	<0.0049	0.1
02/10/2017 12:56	Asulam	ug/l	<0.0049	0.1
18/09/2017 07:47	Asulam	ug/l	<0.0049	0.1
04/09/2017 13:07	Asulam	ug/l	<0.0049	0.1
21/08/2017 14:39	Asulam	ug/l	<0.0049	0.1
07/08/2017 15:05	Asulam	ug/l	<0.0049	0.1
17/07/2017 14:46	Asulam	ug/l	<0.0049	0.1
03/07/2017 14:08	Asulam	ug/l	<0.0049	0.1
19/06/2017 13:53	Asulam	ug/l	<0.0049	0.1
05/06/2017 10:51	Asulam	ug/l	<0.0049	0.1
15/05/2017 13:33	Asulam	ug/l	<0.0049	0.1
01/05/2017 12:01	Asulam	ug/l	<0.0049	0.1
17/04/2017 06:16	Asulam	ug/l	<0.0049	0.1
03/04/2017 13:24	Asulam	ug/l	0.006	0.1
20/03/2017 13:29	Asulam	ug/l	<0.0049	0.1
06/03/2017 12:37	Asulam	ug/l	<0.0049	0.1
20/02/2017 06:20	Asulam	ug/l	<0.0049	0.1
06/02/2017 13:35	Asulam	ug/l	<0.0049	0.1
16/01/2017 14:01	Asulam	ug/l	<0.0049	0.1
02/01/2017 13:23	Asulam	ug/l	<0.0030	0.1