

Sample Point	Sample Point Name	Sample Date	Sample Id	Parameter	Result	Units	Fail Type	Consent Lim
U34AFFFF	Kinnegar UWWTR Effluent	08/01/2024	4922449	Biochemical Oxygen Demand (ATU)	1.3	mg/l O2	Pass	25
U34AFFFF	Kinnegar UWWTR Effluent	08/01/2024	4922449	Chemical Oxygen Demand	20.0	mg/l O2	Pass	125
U34AFFFF	Kinnegar UWWTR Effluent	08/01/2024	4922449	Total Nitrogen	5.1	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	09/01/2024	4867388	Biochemical Oxygen Demand (ATU)	1.8	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	09/01/2024	4867388	Chemical Oxygen Demand	31.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	09/01/2024	4867388	Total Nitrogen	11.8	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	09/01/2024	4867370	Biochemical Oxygen Demand (ATU)	2.6	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	09/01/2024	4867370	Chemical Oxygen Demand	46.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	09/01/2024	4867370	Total Nitrogen	12.0	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	09/01/2024	4867384	Biochemical Oxygen Demand (ATU)	3.4	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	09/01/2024	4867384	Chemical Oxygen Demand	45.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	09/01/2024	4867384	Total Nitrogen	15.0	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	25/01/2024	4870239	Biochemical Oxygen Demand (ATU)	6.4	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	25/01/2024	4870239	Chemical Oxygen Demand	37.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	25/01/2024	4870239	Total Nitrogen	3.1	mg/l as N	Pass	15
U34AFFFF	Kinnegar UWWTR Effluent	27/01/2024	4922461	Biochemical Oxygen Demand (ATU)	2.9	mg/l O2	Pass	25
U34AFFFF	Kinnegar UWWTR Effluent	27/01/2024	4922461	Chemical Oxygen Demand	16.0	mg/l O2	Pass	125
U34AFFFF	Kinnegar UWWTR Effluent	27/01/2024	4922461	Total Nitrogen	4.0	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	27/01/2024	4870399	Biochemical Oxygen Demand (ATU)	6.5	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	27/01/2024	4870399	Chemical Oxygen Demand	13.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	27/01/2024	4870399	Total Nitrogen	12.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	13/02/2024	4876989	Biochemical Oxygen Demand (ATU)	2.6	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	13/02/2024	4876989	Chemical Oxygen Demand	64.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	13/02/2024	4876989	Total Nitrogen	11.0	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	13/02/2024	4876987	Biochemical Oxygen Demand (ATU)	3.2	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	13/02/2024	4876987	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	13/02/2024	4876987	Total Nitrogen	14.0	mg/l as N	Pass	10
U34AFFFF	Kinnegar UWWTR Effluent	15/02/2024	4922465	Biochemical Oxygen Demand (ATU)	4.6	mg/l O2	Pass	25
U34AFFFF	Kinnegar UWWTR Effluent	15/02/2024	4922465	Chemical Oxygen Demand	26.0	mg/l O2	Pass	125
U34AFFFF	Kinnegar UWWTR Effluent	15/02/2024	4922465	Total Nitrogen	4.3	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	25/02/2024	4870401	Biochemical Oxygen Demand (ATU)	2.5	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	25/02/2024	4870401	Chemical Oxygen Demand	27.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	25/02/2024	4870401	Total Nitrogen	9.9	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	28/02/2024	4883028	Biochemical Oxygen Demand (ATU)	9.9	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	28/02/2024	4883028	Chemical Oxygen Demand	33.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	28/02/2024	4883028	Total Nitrogen	14.0	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	28/02/2024	4886944	Biochemical Oxygen Demand (ATU)	12.0	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	28/02/2024	4886944	Chemical Oxygen Demand	34.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	28/02/2024	4886944	Total Nitrogen	14.0	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	28/02/2024	4883018	Biochemical Oxygen Demand (ATU)	10.0	mg/l O2	Pass	25

U34AEEFF	Whitehouse UWWTR Effluent	28/02/2024	4883018	Chemical Oxygen Demand	27.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	28/02/2024	4883018	Total Nitrogen	13.0	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	29/02/2024	4922466	Biochemical Oxygen Demand (ATU)	3.6	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	29/02/2024	4922466	Chemical Oxygen Demand	27.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	29/02/2024	4922466	Total Nitrogen	8.1	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	08/03/2024	4893958	Biochemical Oxygen Demand (ATU)	9.2	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	08/03/2024	4893958	Chemical Oxygen Demand	54.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	08/03/2024	4893958	Total Nitrogen	3.7	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	11/03/2024	4888972	Biochemical Oxygen Demand (ATU)	9.7	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	11/03/2024	4888972	Chemical Oxygen Demand	18.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	11/03/2024	4888972	Total Nitrogen	14.0	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	11/03/2024	4922468	Biochemical Oxygen Demand (ATU)	2.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	11/03/2024	4922468	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	11/03/2024	4922468	Total Nitrogen	7.5	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	19/03/2024	4892306	Biochemical Oxygen Demand (ATU)	4.7	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	19/03/2024	4892306	Chemical Oxygen Demand	31.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	19/03/2024	4892306	Total Nitrogen	8.8	mg/l as N	Pass	15
U34AHEFF	Greenisland UWWTR Effluent	19/03/2024	4892205	Biochemical Oxygen Demand (ATU)	3.2	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	19/03/2024	4892205	Chemical Oxygen Demand	36.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	19/03/2024	4892205	Total Nitrogen	4.6	mg/l as N	Pass	15
U34AKEFF	Belfast UWWTR Effluent	27/03/2024	4895361	Biochemical Oxygen Demand (ATU)	6.4	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	27/03/2024	4895361	Chemical Oxygen Demand	13.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	27/03/2024	4895361	Total Nitrogen	6.5	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	27/03/2024	4895359	Biochemical Oxygen Demand (ATU)	21.0	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	27/03/2024	4895359	Chemical Oxygen Demand	14.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	27/03/2024	4895359	Total Nitrogen	10.0	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	29/03/2024	4922469	Biochemical Oxygen Demand (ATU)	1.3	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	29/03/2024	4922469	Chemical Oxygen Demand	13.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	29/03/2024	4922469	Total Nitrogen	3.4	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	03/04/2024	4922476	Biochemical Oxygen Demand (ATU)	1.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	03/04/2024	4922476	Chemical Oxygen Demand	19.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	03/04/2024	4922476	Total Nitrogen	3.7	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	04/04/2024	4888982	Biochemical Oxygen Demand (ATU)	6.3	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	04/04/2024	4888982	Chemical Oxygen Demand	24.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	04/04/2024	4888982	Total Nitrogen	9.6	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	12/04/2024	4901619	Biochemical Oxygen Demand (ATU)	1.9	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	12/04/2024	4901619	Chemical Oxygen Demand	20.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	12/04/2024	4901619	Total Nitrogen	5.5	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	12/04/2024	4901612	Biochemical Oxygen Demand (ATU)	3.7	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	12/04/2024	4901612	Chemical Oxygen Demand	24.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	12/04/2024	4901612	Total Nitrogen	7.1	mg/l as N	Pass	10

U34AGEFF	Carrickfergus UWWTR Effluent	15/04/2024	4903643	Biochemical Oxygen Demand (ATU)	6.3	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	15/04/2024	4903643	Chemical Oxygen Demand	37.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	15/04/2024	4903643	Total Nitrogen	9.9	mg/l as N	Pass	15
U34AEFF	Kinnegar UWWTR Effluent	22/04/2024	4922477	Biochemical Oxygen Demand (ATU)	1.8	mg/l O2	Pass	25
U34AEFF	Kinnegar UWWTR Effluent	22/04/2024	4922477	Chemical Oxygen Demand	24.0	mg/l O2	Pass	125
U34AEFF	Kinnegar UWWTR Effluent	22/04/2024	4922477	Total Nitrogen	7.2	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	23/04/2024	4906846	Biochemical Oxygen Demand (ATU)	5.1	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	23/04/2024	4906846	Chemical Oxygen Demand	57.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	23/04/2024	4906846	Total Nitrogen	6.6	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	23/04/2024	4906842	Biochemical Oxygen Demand (ATU)	2.1	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	23/04/2024	4906842	Chemical Oxygen Demand	31.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	23/04/2024	4906842	Total Nitrogen	6.7	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	26/04/2024	4907384	Biochemical Oxygen Demand (ATU)	7.0	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	26/04/2024	4907384	Chemical Oxygen Demand	38.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	26/04/2024	4907384	Total Nitrogen	11.0	mg/l as N	Pass	10
U34AEFF	Kinnegar UWWTR Effluent	15/05/2024	4922418	Biochemical Oxygen Demand (ATU)	3.4	mg/l O2	Pass	25
U34AEFF	Kinnegar UWWTR Effluent	15/05/2024	4922418	Chemical Oxygen Demand	20.0	mg/l O2	Pass	125
U34AEFF	Kinnegar UWWTR Effluent	15/05/2024	4922418	Total Nitrogen	6.1	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	17/05/2024	4916123	Biochemical Oxygen Demand (ATU)	6.5	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	17/05/2024	4916123	Chemical Oxygen Demand	29.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	17/05/2024	4916123	Total Nitrogen	9.3	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	17/05/2024	4916116	Biochemical Oxygen Demand (ATU)	5.6	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	17/05/2024	4916116	Chemical Oxygen Demand	20.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	17/05/2024	4916116	Total Nitrogen	8.7	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	23/05/2024	4919031	Biochemical Oxygen Demand (ATU)	21.0	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	23/05/2024	4919031	Chemical Oxygen Demand	86.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	23/05/2024	4919031	Total Nitrogen	13.0	mg/l as N	Pass	15
U34AEFF	Kinnegar UWWTR Effluent	30/05/2024	4922420	Biochemical Oxygen Demand (ATU)	7.8	mg/l O2	Pass	25
U34AEFF	Kinnegar UWWTR Effluent	30/05/2024	4922420	Chemical Oxygen Demand	29.0	mg/l O2	Pass	125
U34AEFF	Kinnegar UWWTR Effluent	30/05/2024	4922420	Total Nitrogen	5.6	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	31/05/2024	4921979	Biochemical Oxygen Demand (ATU)	7.2	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	31/05/2024	4921979	Chemical Oxygen Demand	42.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	31/05/2024	4921979	Total Nitrogen	6.3	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	31/05/2024	4921974	Biochemical Oxygen Demand (ATU)	4.8	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	31/05/2024	4921974	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	31/05/2024	4921974	Total Nitrogen	7.6	mg/l as N	Pass	10
U34AEFF	Kinnegar UWWTR Effluent	10/06/2024	4927444	Biochemical Oxygen Demand (ATU)	5.6	mg/l O2	Pass	25
U34AEFF	Kinnegar UWWTR Effluent	10/06/2024	4927444	Chemical Oxygen Demand	33.0	mg/l O2	Pass	125
U34AEFF	Kinnegar UWWTR Effluent	10/06/2024	4927444	Total Nitrogen	7.5	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	11/06/2024	4927674	Biochemical Oxygen Demand (ATU)	4.8	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	11/06/2024	4927674	Chemical Oxygen Demand	44.0	mg/l O2	Pass	125

U34AKEFF	Belfast UWWTR Effluent	11/06/2024	4927674	Total Nitrogen	6.7	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	11/06/2024	4927669	Biochemical Oxygen Demand (ATU)	2.9	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	11/06/2024	4927669	Chemical Oxygen Demand	36.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	11/06/2024	4927669	Total Nitrogen	8.5	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	15/06/2024	4928267	Biochemical Oxygen Demand (ATU)	4.8	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	15/06/2024	4928267	Chemical Oxygen Demand	55.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	15/06/2024	4928267	Total Nitrogen	5.7	mg/l as N	Pass	15
U34AGEFF	Carrickfergus UWWTR Effluent	15/06/2024	4928265	Biochemical Oxygen Demand (ATU)	6.5	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	15/06/2024	4928265	Chemical Oxygen Demand	37.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	15/06/2024	4928265	Total Nitrogen	14.0	mg/l as N	Pass	15
U34AKEFF	Belfast UWWTR Effluent	19/06/2024	4937888	Biochemical Oxygen Demand (ATU)	3.5	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	19/06/2024	4937888	Chemical Oxygen Demand	57.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	19/06/2024	4937888	Total Nitrogen	7.2	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	25/06/2024	4933637	Biochemical Oxygen Demand (ATU)	2.5	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	25/06/2024	4933637	Chemical Oxygen Demand	39.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	25/06/2024	4933637	Total Nitrogen	13.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	27/06/2024	4933876	Biochemical Oxygen Demand (ATU)	6.9	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	27/06/2024	4933876	Chemical Oxygen Demand	51.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	27/06/2024	4933876	Total Nitrogen	8.4	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	27/06/2024	4933870	Biochemical Oxygen Demand (ATU)	9.2	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	27/06/2024	4933870	Chemical Oxygen Demand	28.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	27/06/2024	4933870	Total Nitrogen	10.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	18/07/2024	4943422	Biochemical Oxygen Demand (ATU)	4.3	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	18/07/2024	4943422	Chemical Oxygen Demand	25.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	18/07/2024	4943422	Total Nitrogen	8.0	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	18/07/2024	4943418	Biochemical Oxygen Demand (ATU)	9.0	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	18/07/2024	4943418	Chemical Oxygen Demand	30.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	18/07/2024	4943418	Total Nitrogen	9.7	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	26/07/2024	4946854	Biochemical Oxygen Demand (ATU)	6.0	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	26/07/2024	4946854	Chemical Oxygen Demand	83.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	26/07/2024	4946854	Total Nitrogen	2.3	mg/l as N	Pass	15
U34AKEFF	Belfast UWWTR Effluent	29/07/2024	4949378	Biochemical Oxygen Demand (ATU)	5.2	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	29/07/2024	4949378	Chemical Oxygen Demand	47.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	29/07/2024	4949378	Total Nitrogen	5.9	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	29/07/2024	4949370	Biochemical Oxygen Demand (ATU)	1.2	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	29/07/2024	4949370	Chemical Oxygen Demand	18.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	29/07/2024	4949370	Total Nitrogen	9.1	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	06/08/2024	4943425	Biochemical Oxygen Demand (ATU)	5.7	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	06/08/2024	4943425	Chemical Oxygen Demand	27.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	06/08/2024	4943425	Total Nitrogen	6.7	mg/l as N	Pass	15
U34AGEFF	Carrickfergus UWWTR Effluent	14/08/2024	4955642	Biochemical Oxygen Demand (ATU)	2.4	mg/l O2	Pass	25

U34AGEFF	Carrickfergus UWWTR Effluent	14/08/2024	4955642	Chemical Oxygen Demand	34.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	14/08/2024	4955642	Total Nitrogen	8.3	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	14/08/2024	4955635	Biochemical Oxygen Demand (ATU)	4.8	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	14/08/2024	4955635	Chemical Oxygen Demand	23.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	14/08/2024	4955635	Total Nitrogen	8.3	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	19/08/2024	4939952	Biochemical Oxygen Demand (ATU)	5.3	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	19/08/2024	4939952	Chemical Oxygen Demand	38.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	19/08/2024	4939952	Total Nitrogen	7.5	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	22/08/2024	4958861	Biochemical Oxygen Demand (ATU)	2.6	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	22/08/2024	4958861	Chemical Oxygen Demand	30.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	22/08/2024	4958861	Total Nitrogen	3.9	mg/l as N	Pass	15
U34AFEFF	Kinnegar UWWTR Effluent	29/08/2024	4965622	Biochemical Oxygen Demand (ATU)	5.2	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	29/08/2024	4965622	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	29/08/2024	4965622	Total Nitrogen	5.8	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	30/08/2024	4961934	Biochemical Oxygen Demand (ATU)	3.6	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	30/08/2024	4961934	Chemical Oxygen Demand	33.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	30/08/2024	4961934	Total Nitrogen	7.3	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	30/08/2024	4961932	Biochemical Oxygen Demand (ATU)	2.9	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	30/08/2024	4961932	Chemical Oxygen Demand	20.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	30/08/2024	4961932	Total Nitrogen	9.3	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	02/09/2024	4955639	Biochemical Oxygen Demand (ATU)	3.2	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	02/09/2024	4955639	Chemical Oxygen Demand	38.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	02/09/2024	4955639	Total Nitrogen	7.8	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	02/09/2024	4961435	Biochemical Oxygen Demand (ATU)	1.6	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	02/09/2024	4961435	Chemical Oxygen Demand	50.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	02/09/2024	4961435	Total Nitrogen	8.9	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	10/09/2024	4967836	Biochemical Oxygen Demand (ATU)	3.2	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	10/09/2024	4967836	Chemical Oxygen Demand	32.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	10/09/2024	4967836	Total Nitrogen	8.6	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	10/09/2024	4967838	Biochemical Oxygen Demand (ATU)	3.9	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	10/09/2024	4967838	Chemical Oxygen Demand	43.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	10/09/2024	4967838	Total Nitrogen	8.1	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	13/09/2024	4968287	Biochemical Oxygen Demand (ATU)	8.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	13/09/2024	4968287	Chemical Oxygen Demand	32.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	13/09/2024	4968287	Total Nitrogen	8.8	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	16/09/2024	4970952	Chemical Oxygen Demand	25.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	16/09/2024	4970952	Total Nitrogen	7.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	17/09/2024	4971131	Biochemical Oxygen Demand (ATU)	3.5	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	17/09/2024	4971131	Chemical Oxygen Demand	36.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	17/09/2024	4971131	Total Nitrogen	8.0	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	17/09/2024	4967842	Biochemical Oxygen Demand (ATU)	1.4	mg/l O2	Pass	25

U34AGEFF	Carrickfergus UWWTR Effluent	17/09/2024	4967842	Chemical Oxygen Demand	34.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	17/09/2024	4967842	Total Nitrogen	11.0	mg/l as N	Pass	15
U34AHEFF	Greenisland UWWTR Effluent	17/09/2024	4971138	Biochemical Oxygen Demand (ATU)	1.8	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	17/09/2024	4971138	Chemical Oxygen Demand	55.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	17/09/2024	4971138	Total Nitrogen	3.1	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	17/09/2024	4971128	Chemical Oxygen Demand	26.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	17/09/2024	4971128	Total Nitrogen	9.5	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	18/09/2024	4971373	Biochemical Oxygen Demand (ATU)	6.9	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	18/09/2024	4971373	Chemical Oxygen Demand	31.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	27/09/2024	4973558	Biochemical Oxygen Demand (ATU)	17.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	27/09/2024	4973558	Chemical Oxygen Demand	38.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	27/09/2024	4973558	Total Nitrogen	11.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	13/10/2024	4983487	Biochemical Oxygen Demand (ATU)	4.1	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	13/10/2024	4983487	Chemical Oxygen Demand	26.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	13/10/2024	4983487	Total Nitrogen	5.6	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	13/10/2024	4983497	Biochemical Oxygen Demand (ATU)	7.2	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	13/10/2024	4983497	Chemical Oxygen Demand	25.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	13/10/2024	4983497	Total Nitrogen	5.9	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	13/10/2024	4983485	Biochemical Oxygen Demand (ATU)	8.5	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	13/10/2024	4983485	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	13/10/2024	4983485	Total Nitrogen	9.8	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	15/10/2024	4983611	Biochemical Oxygen Demand (ATU)	5.3	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	15/10/2024	4983611	Chemical Oxygen Demand	36.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	15/10/2024	4983611	Total Nitrogen	9.5	mg/l as N	Pass	15
U34AHEFF	Greenisland UWWTR Effluent	23/10/2024	4988202	Biochemical Oxygen Demand (ATU)	7.5	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	23/10/2024	4988202	Chemical Oxygen Demand	52.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	23/10/2024	4988202	Total Nitrogen	6.2	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	29/10/2024	4988866	Biochemical Oxygen Demand (ATU)	2.3	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	29/10/2024	4988861	Biochemical Oxygen Demand (ATU)	6.5	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	29/10/2024	4988861	Chemical Oxygen Demand	18.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	29/10/2024	4988861	Total Nitrogen	5.4	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	31/10/2024	4989150	Biochemical Oxygen Demand (ATU)	4.2	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	31/10/2024	4989150	Chemical Oxygen Demand	41.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	31/10/2024	4989150	Total Nitrogen	8.2	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	31/10/2024	4989147	Biochemical Oxygen Demand (ATU)	2.6	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	31/10/2024	4989147	Chemical Oxygen Demand	23.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	31/10/2024	4989147	Total Nitrogen	11.0	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	03/11/2024	4994433	Biochemical Oxygen Demand (ATU)	27.0	mg/l O2	UWWTR Fail	25
U34AFEFF	Kinnegar UWWTR Effluent	03/11/2024	4994433	Chemical Oxygen Demand	43.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	11/11/2024	4994984	Biochemical Oxygen Demand (ATU)	4.3	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	11/11/2024	4994984	Chemical Oxygen Demand	36.0	mg/l O2	Pass	125

U34AKEFF	Belfast UWWTR Effluent	11/11/2024	4994984	Total Nitrogen	7.0	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	11/11/2024	4994989	Biochemical Oxygen Demand (ATU)	8.8	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	11/11/2024	4994989	Chemical Oxygen Demand	34.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	11/11/2024	4994989	Total Nitrogen	15.0	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	11/11/2024	4994979	Biochemical Oxygen Demand (ATU)	3.0	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	11/11/2024	4994979	Chemical Oxygen Demand	31.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	11/11/2024	4994979	Total Nitrogen	9.3	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	12/11/2024	4995320	Biochemical Oxygen Demand (ATU)	3.2	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	12/11/2024	4995320	Chemical Oxygen Demand	38.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	12/11/2024	4995320	Total Nitrogen	9.4	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	19/11/2024	4998311	Biochemical Oxygen Demand (ATU)	5.1	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	19/11/2024	4998311	Chemical Oxygen Demand	110.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	19/11/2024	4998311	Total Nitrogen	5.2	mg/l as N	Pass	15
U34AFEFF	Kinnegar UWWTR Effluent	26/11/2024	5001297	Biochemical Oxygen Demand (ATU)	2.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	26/11/2024	5001297	Chemical Oxygen Demand	23.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	26/11/2024	5001297	Total Nitrogen	3.8	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	26/11/2024	5001329	Biochemical Oxygen Demand (ATU)	1.8	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	26/11/2024	5001329	Chemical Oxygen Demand	22.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	26/11/2024	5001329	Total Nitrogen	9.1	mg/l as N	Pass	10
U34AEEFF	Whitehouse UWWTR Effluent	27/11/2024	5001460	Biochemical Oxygen Demand (ATU)	8.8	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	27/11/2024	5001460	Chemical Oxygen Demand	33.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	27/11/2024	5001460	Total Nitrogen	9.8	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	09/12/2024	5009379	Biochemical Oxygen Demand (ATU)	12.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	09/12/2024	5009379	Chemical Oxygen Demand	60.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	09/12/2024	5009379	Total Nitrogen	11.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	13/12/2024	5010280	Biochemical Oxygen Demand (ATU)	5.3	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	13/12/2024	5010280	Chemical Oxygen Demand	24.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	13/12/2024	5010280	Total Nitrogen	10.0	mg/l as N	Pass	10
U34AHEFF	Greenisland UWWTR Effluent	13/12/2024	5010283	Biochemical Oxygen Demand (ATU)	6.2	mg/l O2	Pass	25
U34AHEFF	Greenisland UWWTR Effluent	13/12/2024	5010283	Chemical Oxygen Demand	61.0	mg/l O2	Pass	125
U34AHEFF	Greenisland UWWTR Effluent	13/12/2024	5010283	Total Nitrogen	6.9	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	13/12/2024	5010275	Biochemical Oxygen Demand (ATU)	4.9	mg/l O2	Pass	25
U34AEEFF	Whitehouse UWWTR Effluent	13/12/2024	5010275	Chemical Oxygen Demand	26.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	13/12/2024	5010275	Total Nitrogen	13.0	mg/l as N	Pass	10
U34AKEFF	Belfast UWWTR Effluent	16/12/2024	5011674	Biochemical Oxygen Demand (ATU)	2.2	mg/l O2	Pass	25
U34AKEFF	Belfast UWWTR Effluent	16/12/2024	5011674	Chemical Oxygen Demand	30.0	mg/l O2	Pass	125
U34AKEFF	Belfast UWWTR Effluent	16/12/2024	5011674	Total Nitrogen	8.4	mg/l as N	Pass	10
U34AGEFF	Carrickfergus UWWTR Effluent	16/12/2024	5011678	Biochemical Oxygen Demand (ATU)	5.8	mg/l O2	Pass	25
U34AGEFF	Carrickfergus UWWTR Effluent	16/12/2024	5011678	Chemical Oxygen Demand	94.0	mg/l O2	Pass	125
U34AGEFF	Carrickfergus UWWTR Effluent	16/12/2024	5011678	Total Nitrogen	11.0	mg/l as N	Pass	15
U34AEEFF	Whitehouse UWWTR Effluent	16/12/2024	5011670	Biochemical Oxygen Demand (ATU)	3.5	mg/l O2	Pass	25

U34AEEFF	Whitehouse UWWTR Effluent	16/12/2024	5011670	Chemical Oxygen Demand	33.0	mg/l O2	Pass	125
U34AEEFF	Whitehouse UWWTR Effluent	16/12/2024	5011670	Total Nitrogen	9.2	mg/l as N	Pass	10
U34AFEFF	Kinnegar UWWTR Effluent	18/12/2024	5012119	Biochemical Oxygen Demand (ATU)	19.0	mg/l O2	Pass	25
U34AFEFF	Kinnegar UWWTR Effluent	18/12/2024	5012119	Chemical Oxygen Demand	37.0	mg/l O2	Pass	125
U34AFEFF	Kinnegar UWWTR Effluent	18/12/2024	5012119	Total Nitrogen	9.0	mg/l as N	Pass	10